



TEST REPORT

Report Number..... : **ZKT-2312220309E**

Date of Test..... : Dec. 22, 2023 to Dec. 29, 2023

Date of issue..... : Dec. 29, 2023

Total number of pages..... : 35

Test Result : PASS

Testing Laboratory..... : **Shenzhen ZKT Technology Co., Ltd.**

Address : 1/F, No. 101, Building B, No. 6, Tangwei Community Industrial Avenue, Fuhai Street, Bao'an District, Shenzhen, China

Applicant's name : **Zhongshan Yiheng Electrical Equipment Co.,Ltd**

Address : 7th floor, elevator 2, No.1 Fuqing 1st Road, Henglan Town, Zhongshan City

Manufacturer's name : **Zhongshan Yiheng Electrical Equipment Co.,Ltd**

Address : 7th floor, elevator 2, No.1 Fuqing 1st Road, Henglan Town, Zhongshan City

Test specification:

Standard..... : EN IEC 55014-1:2021, EN IEC 55014-2:2021,
EN IEC 61000-3-2:2019/A1:2021,
EN 61000-3-3:2013/A2:2021,
EN 61000-4-2:2009, EN IEC 61000-4-3:2020,
EN 61000-4-4:2012, EN 61000-4-5:2014+A1:2017,
EN IEC 61000-4-6:2023, EN 61000-4-8:2010,
EN IEC 61000-4-11:2020

Test procedure..... : CE-EMC

Non-standard test method : N/A

Test Report Form No..... : TRF-EL-142 V0

Test Report Form(s) Originator..... : ZKT Testing

Master TRF : Dated: 2020-01-06

This device described above has been tested by ZKT, and the test results show that the equipment under test (EUT) is in compliance with the 2014/30/EU Directive requirements. And it is applicable only to the tested sample identified in the report.

This report shall not be reproduced except in full, without the written approval of ZKT, this document may be altered or revised by ZKT, personal only, and shall be noted in the revision of the document.

Product name..... : **Water vapor fireplace**

Trademark : N/A

Model/Type reference..... : YH-1000S

YH-800S、YH-1200S、YH-1500S、YH-1800S、YH-2000S

Ratings..... : Input: AC 220~240V, 50Hz



Testing procedure and testing location:

Testing Laboratory.....: Shenzhen ZKT Technology Co., Ltd.

**Address.....: 1/F, No. 101, Building B, No. 6, Tangwei Community
Industrial Avenue, Fuhai Street, Bao'an District,
Shenzhen, China**

Tested by (name + signature).....: Jim Liu

Jim Liu

Reviewer (name + signature).....: Jackson Fang

Jackson Fang

Approved (name + signature).....: Lake Xie





TABLE OF CONTENT

	Page
1. VERSION	5
2. GENERAL INFORMATION	6
2.1 Description of Device (EUT)	6
2.2 Tested System Details	6
2.3 Test Facility	6
2.4 MEASUREMENT UNCERTAINTY	6
2.5 Test Instrument Used	7
3. CONDUCTED EMISSION AT THE MAINS TERMINALS TEST	9
3.1 Block Diagram Of Test Setup	9
3.2 Test Standard	9
3.3 Power Line Conducted Emission Limit	9
3.4 EUT Configuration on Test	9
3.5 Operating Condition of EUT	9
3.6 Test Procedure	9
3.7 Test Result	9
4. RADIATION EMISSION TEST	12
4.1 Block Diagram of Test Setup	12
4.2 Test Standard	12
4.3 Radiation Limit	12
4.4 EUT Configuration on Test	12
4.5 Operating Condition of EUT	12
4.6 Test Procedure	13
4.7 Test Result	13
5. HARMONIC CURRENT EMISSION TEST	16
5.1 Block Diagram of Test Setup	16
5.2 Test Standard	16
5.3 Operating Condition of EUT	16
5.4 Test Procedure	16
5.5 Test Results	16
6. VOLTAGE FLUCTUATIONS & FLICKER TEST	19
6.1 Block Diagram of Test Setup	19
6.2 Test Standard	19
6.3 Operating Condition of EUT	19
6.4 Test Procedure	19
6.5 Test Results	19
7. ELECTROSTATIC DISCHARGE IMMUNITY TEST	20
7.1 Block Diagram of Test Setup	20
7.2 Test Standard	20
7.3 Severity Levels and Performance Criterion	20
7.4 EUT Configuration	21
7.5 Operating Condition of EUT	21
7.6 Test Procedure	21
7.7 Test Results	21
8. RF FIELD STRENGTH SUSCEPTIBILITY TEST	23
8.1 Block Diagram of Test Setup	23
8.2 Test Standard	23
8.3 Severity Levels and Performance Criterion	23
8.4 EUT Configuration on Test	24
8.5 Operating Condition of EUT	24
8.6 Test Procedure	24
8.7 Test Results	24



9. ELECTRICAL FAST TRANSIENT/BURST IMMUNITY TEST	26
9.1 Block Diagram of EUT Test Setup	26
9.2 Test Standard	26
9.3 Severity Levels and Performance Criterion	26
9.4 EUT Configuration on Test	27
9.5 Operating Condition of EUT	27
9.6 Test Procedure	27
9.7 Test Results	27
10. SURGE TEST	28
10.1 Block Diagram of EUT Test Setup	28
10.2 Test Standard	28
10.3 Severity Levels and Performance Criterion	28
10.4 EUT Configuration on Test	29
10.5 Operating Condition of EUT	29
10.6 Test Procedure	29
10.7 Test Result	29
11. INJECTED CURRENTS SUSCEPTIBILITY TEST	30
11.1 Block Diagram of EUT Test Setup	30
11.2 Test Standard	30
11.3 Severity Levels and Performance Criterion	30
11.4 EUT Configuration on Test	30
11.5 Operating Condition of EUT	30
11.6 Test Procedure	31
11.7 Test Result	31
12. VOLTAGE DIPS AND INTERRUPTIONS TEST	32
12.1 Block Diagram of EUT Test Setup	32
12.2 Test Standard	32
12.3 Severity Levels and Performance Criterion	32
12.4 EUT Configuration on Test	32
12.5 Operating Condition of EUT	32
12.6 Test Procedure	33
12.7 Test Result	33
13. EUT PHOTOGRAPHS	34
14. EUT TEST PHOTOGRAPHS	35



1. VERSION

Report No.	Version	Description	Approved
ZKT-2312220309E	Rev.01	Initial issue of report	Dec. 29, 2023



2. GENERAL INFORMATION

2.1 Description of Device (EUT)

EUT	:	Water vapor fireplace
Model Number	:	YH-1000S YH-800S、YH-1200S、YH-1500S、YH-1800S、YH-2000S
Trademark	:	N/A
Model Difference	:	Only for different model name
Power Supply	:	Input: AC 220~240V, 50Hz

Note:

2.2 Tested System Details

None.

2.3 Test Facility

Site Description

Name of Firm : Shenzhen ZKT Technology Co., Ltd.

Site Location : 1/F, No. 101, Building B, No. 6, Tangwei Community Industrial Avenue, Fuhai Street, Bao'an District, Shenzhen, China

2.4 MEASUREMENT UNCERTAINTY

Where relevant, the following measurement uncertainty levels have been estimated for tests performed on the Product as specified in CISPR 16-4-2. This uncertainty represents an expanded uncertainty expressed at approximately the 95% confidence level using a coverage factor of $k=2$.

Test item	Value (dB)
Conducted Emission (150K-30MHZ)	3.20
Radiated disturbance30MHz-1000MHz	4.80

Please refer to the following page.



2.5 Test Instrument Used

Conducted emissions & Magnetic Emission & Disturbance power Test

Item	Kind of Equipment	Manufacturer	Type No.	Serial No.	Firmware Version	Last calibration	Calibrated until
1	LISN	R&S	ENV216	101471	N/A	Nov. 14, 2023	Nov. 13, 2024
2	LISN	CYBERTEK	EM5040A	E1850400149	N/A	Nov. 02, 2023	Nov. 01, 2024
3	Test Cable	N/A	C-01	N/A	N/A	Nov. 02, 2023	Nov. 01, 2024
4	Test Cable	N/A	C-02	N/A	N/A	Nov. 02, 2023	Nov. 01, 2024
5	Test Cable	N/A	C-03	N/A	N/A	Nov. 02, 2023	Nov. 01, 2024
6	EMI Test Receiver	R&S	ESCI3	101393	4.42 SP3	Nov. 02, 2023	Nov. 01, 2024
7	Triple-Loop Antenna	N/A	RF300	N/A	N/A	Nov. 02, 2023	Nov. 01, 2024
8	Absorbing Clamp	DZ	ZN23201	15034	N/A	Nov. 07, 2023	Nov. 06, 2024
9	EMC Software	Frad	EZ-EMC	Ver.EMC-CO N 3A1.1	N/A	\	\

Harmonic / Flicker Test

Item	Kind of Equipment	Manufacturer	Type No.	Serial No.	Firmware Version	Last calibration	Calibrated until
1	Harmonic & Flicker	HTEC Instruments	AC2000A	548549	1.21	Nov. 02, 2023	Nov. 01, 2024
2	AC Power Source	/	HPHF4010	JN102209079 5	DAL40	Nov. 02, 2023	Nov. 01, 2024

Electrostatic discharge Test

Item	Kind of Equipment	Manufacturer	Type No.	Serial No.	Firmware Version	Last calibration	Calibrated until
1	ESD TEST GENERATOR	HTEC	HESD16	N/A	004307	Nov. 08, 2023	Nov. 07, 2024

EFT and Surge and Voltage dips and interruptions Test

Item	Kind of Equipment	Manufacturer	Type No.	Serial No.	Firmware Version	Last calibration	Calibrated until
1	Surge Generator	HTEC	HCOMPACT 5	N/A	V1.3.4	Nov. 02, 2023	Nov. 01, 2024
2	DIPS Generator	HTEC	HV1P16T	202101	V1.3.4	Nov. 02, 2023	Nov. 01, 2024
3	EFT/B Generator	HTEC	HCOMPACT 5	N/A	V1.3.4	Nov. 02, 2023	Nov. 01, 2024
4	EFT/B Clamp	HTEC	H3C	N/A	N/A	Nov. 02, 2023	Nov. 01, 2024

For Magnetic Field Immunity Test

Item	Kind of Equipment	Manufacturer	Type No.	Serial No.	Firmware Version	Last calibration	Calibrated until
1	Generator	HTEC	HFMG 100	202602	V2.1-182802	Nov. 02, 2023	Nov. 01, 2024

Radio-frequency fields Immunity Test

Item	Kind of Equipment	Manufacturer	Type No.	Serial No.	Firmware Version	Last calibration	Calibrated until
1	Signal Generator	TESEQ	NSG4070-75	31477	V1.30	Nov. 02, 2023	Nov. 01, 2024
2	CDN	SCHWARZBECK	CDN M2/M3PE 16A	00128	N/A	Nov. 02, 2023	Nov. 01, 2024
3	Attenuator	GuoRenTong Xin	SGR-SJQ-6dB- DC-3	N/A	N/A	Nov. 02, 2023	Nov. 01, 2024




Radiation Test equipment

Item	Equipment	Manufacturer	Type No.	Serial No.	Firmware Version	Last calibration	Calibrated until
1	Spectrum Analyzer (9kHz-26.5GHz)	KEYSIGHT	9020A	MY55370835	A.17.05	Nov. 02, 2023	Nov. 01, 2024
2	Spectrum Analyzer (10kHz-39.9GHz)	R&S	FSV40-N	100363	1.71 SP2	Nov. 02, 2023	Nov. 01, 2024
3	EMI Test Receiver (9kHz-7GHz)	R&S	ESCI7	100969	4.32	Nov. 02, 2023	Nov. 01, 2024
4	Bilog Antenna (30MHz-1500MHz)	Schwarzbeck	VULB9168	N/A	N/A	Nov. 13, 2023	Nov. 12, 2024
5	Horn Antenna (1GHz-18GHz)	Agilent	AH-118	071145	N/A	Nov. 13, 2023	Nov. 12, 2024
6	Horn Antenna (15GHz-40GHz)	A.H.System	SAS-574	588	N/A	Nov. 13, 2023	Nov. 12, 2024
7	Loop Antenna	TESEQ	HLA6121	58357	N/A	Nov. 16, 2023	Nov. 15, 2024
8	Amplifier (30-1000MHz)	EM Electronics	EM330 Amplifier	60747	N/A	Nov. 02, 2023	Nov. 01, 2024
9	Amplifier (1GHz-26.5GHz)	HuiPu	8449B	3008A00315	N/A	Nov. 02, 2023	Nov. 01, 2024
10	Amplifier (500MHz-40GHz)	QuanJuDa	DLE-161	097	N/A	Nov. 02, 2023	Nov. 01, 2024
11	Test Cable	N/A	R-01	N/A	N/A	Nov. 02, 2023	Nov. 01, 2024
12	Test Cable	N/A	R-02	N/A	N/A	Nov. 02, 2023	Nov. 01, 2024
13	Test Cable	N/A	R-03	N/A	N/A	Nov. 02, 2023	Nov. 01, 2024
14	Test Cable	N/A	RF-01	N/A	N/A	Nov. 02, 2023	Nov. 01, 2024
15	Test Cable	N/A	RF-02	N/A	N/A	Nov. 02, 2023	Nov. 01, 2024
16	Test Cable	N/A	RF-03	N/A	N/A	Nov. 02, 2023	Nov. 01, 2024
17	ESG Signal Generator	Agilent	E4421B	N/A	B.03.84	Nov. 02, 2023	Nov. 01, 2024
18	Signal Generator	Agilent	N5182A	N/A	A.01.87	Nov. 02, 2023	Nov. 01, 2024
19	Magnetic Field Probe Tester	Narda	ELT-400	0-0344	N/A	Nov. 16, 2023	Nov. 15, 2024
20	Wideband Radio Communication Test	R&S	CMW500	106504	V 3.7.22	Nov. 02, 2023	Nov. 01, 2024
21	MWRF Power Meter Test system	MW	MW100-RF CB	N/A	N/A	Nov. 02, 2023	Nov. 01, 2024
22	D.C. Power Supply	LongWei	TPR-6405D	N/A	N/A	\	\
23	EMC Software	Frad	EZ-EMC	Ver.EMC-C ON 3A1.1	N/A	\	\
24	RF Software	MW	MTS8310	V2.0.0.0	N/A	\	\
25	Turntable	MF	MF-7802BS	N/A	N/A	\	\
26	Antenna tower	MF	MF-7802BS	N/A	N/A	\	\



3. CONDUCTED EMISSION AT THE MAINS TERMINALS TEST

3.1 Block Diagram Of Test Setup



3.2 Test Standard

EN IEC 55014-1:2021

3.3 Power Line Conducted Emission Limit

Frequency MHz	Limits dB(μV)	
	Quasi-peak Level	Average Level
0.15 ~ 0.50	66 ~ 56*	59 ~ 46*
0.50 ~ 5.00	56	46
5.00 ~ 30.00	60	50

Notes: 1. *Decreasing linearly with logarithm of frequency.
2. The lower limit shall apply at the transition frequencies.

3.4 EUT Configuration on Test

The following equipments are installed on conducted emission test to meet EN 55014-1 requirement and operating in a manner which tends to maximize its emission characteristics in a normal application.

3.5 Operating Condition of EUT

- 3.5.1 Setup the EUT and simulators as shown in Section 3.1.
- 3.5.2 Turn on the power of all equipments.
- 3.5.3 Let the EUT work in test modes and test it.

3.6 Test Procedure

The EUT is put on the ground and connected to the AC mains through a Artificial Mains Network (AMN). This provided a 50ohm coupling impedance for the tested equipments. Both sides of AC line are checked to find out the maximum conducted emission levels according to the **EN55014-1** regulations during conducted emission test.

The bandwidth of the test receiver (R&S Test Receiver ESCI) is set at 10KHz.

The frequency range from 150 KHz to 30 MHz is investigated.

3.7 Test Result


Pass

Please refer to the following page.



Conducted Emission At The Mains Terminals Test Data

Temperature:	26℃	Relative Humidity:	60%
Pressure:	1009hPa	Phase :	Line
Test Voltage :	AC 230V 50Hz	Test Mode:	Working




No.	Frequency (MHz)	Reading (dBuV)	Factor (dB)	Level (dBuV)	Limit (dBuV)	Margin (dB)	Detector	P/F	Remark
1	0.1860	25.07	12.23	37.30	64.21	-26.91	QP	P	
2	0.1860	15.48	12.23	27.71	56.68	-28.97	AVG	P	
3	0.2220	15.62	11.82	27.44	54.77	-27.33	AVG	P	
4	0.2265	26.31	11.80	38.11	62.58	-24.47	QP	P	
5	0.3120	14.50	11.41	25.91	51.09	-25.18	AVG	P	
6	0.3209	25.35	11.37	36.72	59.68	-22.96	QP	P	
7	0.3975	24.58	11.01	35.59	57.91	-22.32	QP	P	
8	0.4065	14.26	10.97	25.23	48.24	-23.01	AVG	P	
9	0.6269	24.50	10.51	35.01	56.00	-20.99	QP	P	
10	0.6269	13.00	10.51	23.51	46.00	-22.49	AVG	P	
11	1.3919	16.48	10.34	26.82	46.00	-19.18	AVG	P	
12	1.3964	26.10	10.34	36.44	56.00	-19.56	QP	P	



Conducted Emission At The Mains Terminals Test Data

Temperature:	26℃	Relative Humidity:	60%
Pressure:	1009hPa	Phase :	Neutral
Test Voltage :	AC 230V 50Hz	Test Mode:	Working




No.	Frequency (MHz)	Reading (dBuV)	Factor (dB)	Level (dBuV)	Limit (dBuV)	Margin (dB)	Detector	P/F	Remark
1	0.1545	23.26	12.91	36.17	65.75	-29.58	QP	P	
2	0.1545	12.77	12.91	25.68	58.68	-33.00	AVG	P	
3	0.1815	15.04	12.33	27.37	56.94	-29.57	AVG	P	
4	0.1860	25.29	12.23	37.52	64.21	-26.69	QP	P	
5	0.2175	26.06	11.84	37.90	62.91	-25.01	QP	P	
6	0.2220	15.74	11.82	27.56	54.77	-27.21	AVG	P	
7	0.2490	26.41	11.69	38.10	61.79	-23.69	QP	P	
8	0.2490	16.06	11.69	27.75	53.53	-25.78	AVG	P	
9	0.3075	26.75	11.43	38.18	60.04	-21.86	QP	P	
10	0.3075	14.99	11.43	26.42	51.25	-24.83	AVG	P	
11	1.3695	16.24	10.35	26.59	46.00	-19.41	AVG	P	
12	1.3740	26.00	10.35	36.35	56.00	-19.65	QP	P	



4. RADIATION EMISSION TEST

4.1 Block Diagram of Test Setup



4.2 Test Standard

EN IEC 55014-1:2021

4.3 Radiation Limit

Frequency MHz	Distance (Meters)	Field Strengths Limits dB(μV)/m
30 ~ 230	3	40.0
230 ~ 1000	3	47.0

Remark:

- (1) Emission level (dB(μV)/m) = 20 log Emission level (μV/m)
- (2) The smaller limit shall apply at the cross point between two frequency bands.
- (3) Distance refers to the distance in meters between the measuring instrument, antenna and the closed point of any part of the device or system.

4.4 EUT Configuration on Test

The EN 55014-1 regulations test method must be used to find the maximum emission during radiated emission test.

The configuration of EUT is the same as used in conducted emission test.
Please refer to Section 2.2.

4.5 Operating Condition of EUT

Same as conducted emission test, which is listed in Section 2.2 except the test set up replaced as Section 4.1.



4.6 Test Procedure

The EUT and its simulators are placed on a turned table that is 0.8 meter above the ground. The turned table can rotate 360 degrees to determine the position of the maximum emission level. The EUT is set 3 meters away from the receiving antenna that is mounted on the antenna tower. The antenna can move up and down between 1 meter and 4 meters to find out the maximum emission level. Broadband antenna (calibrated biconical and log periodical antenna) is used as receiving antenna. Both horizontal and vertical polarization of the antenna is set on test. In order to find the maximum emission levels, the interface cable must be manipulated according to EN 55014-1 on radiated emission test.

The bandwidth setting on the field strength meter (R&S Test Receiver ESCI) is set at 120KHz.

The frequency range from 30MHz to 1000MHz is checked.


4.7 Test Result

Pass

Please refer to the following page.




Radiation Emission Test Data			
Temperature:	23.8℃	Relative Humidity:	42%
Pressure:	1009hPa	Phase :	Horizontal
Test Voltage :	AC 230V 50Hz	Test Mode:	Working



No.	Frequency (MHz)	Reading (dBuV)	Factor (dB/m)	Level (dBuV/m)	Limit (dBuV/m)	Margin (dB)	Detector	Height (cm)	Azimuth (deg.)	P/F	Remark
1	49.4460	47.65	-17.27	30.38	40.00	-9.62	QP				
2	171.6933	50.01	-19.98	30.03	40.00	-9.97	QP				
3	177.8206	45.62	-19.88	25.74	40.00	-14.26	QP				
4	217.5443	46.07	-20.43	25.64	40.00	-14.36	QP				
5	645.1194	29.74	-7.72	22.02	47.00	-24.98	QP				
6	924.1345	29.78	-0.61	29.17	47.00	-17.83	QP				



Radiation Emission Test Data			
Temperature:	23.8℃	Relative Humidity:	42%
Pressure:	1009hPa	Phase :	Vertical
Test Voltage :	AC 230V 50Hz	Test Mode:	Working




No.	Frequency (MHz)	Reading (dBuV)	Factor (dB/m)	Level (dBuV/m)	Limit (dBuV/m)	Margin (dB)	Detector	Height (cm)	Azimuth (deg.)	P/F	Remark
1	131.9889	43.16	-17.59	25.57	40.00	-14.43	QP				
2	171.6933	44.90	-17.15	27.75	40.00	-12.25	QP				
3	217.5443	45.59	-17.92	27.67	40.00	-12.33	QP				
4	250.3011	42.37	-15.90	26.47	47.00	-20.53	QP				
5	280.5152	38.71	-14.41	24.30	47.00	-22.70	QP				
6	334.2722	40.06	-16.84	23.22	47.00	-23.78	QP				



5. HARMONIC CURRENT EMISSION TEST

5.1 Block Diagram of Test Setup



5.2 Test Standard

EN IEC 61000-3-2:2019/A1:2021

5.3 Operating Condition of EUT



- 5.3.1 Setup the EUT as shown in Section 5.1.
- 5.3.2 Turn on the power of all equipments.
- 5.3.3 Let the EUT work in test mode and test it.

5.4 Test Procedure

The power cord of the EUT is connected to the output of the test system. Turn on the power of the EUT and use the test system to test the harmonic current level.

5.5 Test Results

Pass
Please refer to the following page.





N	Filtered	Limit	Avg.	%Limit	Max.	%Limit	N	Filtered	Limit	Avg.	%Limit	Max.	%Limit
1	446.7			-		-	2	2.3	1080.0	2.5	0.2	2.8	0.3
3	411.8	2300.0	411.3	17.9	411.8	17.9	4	2.3	430.0	2.4	0.6	2.6	0.6
5	366.4	1140.0	366.0	32.1	366.6	32.2	6	2.3	300.0	2.5	0.8	2.6	0.9
7	306.9	770.0	306.5	39.8	307.3	39.9	8	2.1	230.0	2.6	1.1	2.8	1.2
9	241.3	400.0	241.0	60.3	241.8	60.5	10	2.3	184.0	2.6	1.4	3.0	1.6
11	179.6	330.0	179.3	54.3	180.1	54.6	12	2.5	153.3	2.7	1.8	3.0	2.0
13	130.7	210.0	130.4	62.1	131.0	62.4	14	2.5	131.4	2.8	2.1	3.2	2.4
15	101.6	150.0	101.2	67.5	101.7	67.8	16	2.5	115.0	2.8	2.4	3.2	2.8
17	89.7	132.3	89.4	67.6	90.0	68.0	18	2.5	102.2	2.8	2.7	3.2	3.1
19	84.3	118.4	84.0	70.9	84.5	71.4	20	2.5	92.0	2.7	2.9	3.2	3.5
21	76.9	107.1	76.7	71.6	77.3	72.2	22	2.6	83.6	2.7	3.2	3.0	3.6
23	66.8	97.8	66.7	68.2	67.0	68.5	24	2.5	76.7	2.6	3.4	3.0	3.9
25	56.6	90.0	56.4	62.7	56.8	63.1	26	2.5	70.8	2.5	3.5	2.8	4.0
27	49.2	83.3	49.0	58.8	49.4	59.3	28	2.5	65.7	2.5	3.8	2.8	4.3
29	45.3	77.6	45.0	58.0	45.4	58.5	30	2.3	61.3	2.4	3.9	2.6	4.2
31	42.6	72.6	42.4	58.4	42.7	58.8	32	1.9	57.5	2.1	3.7	2.5	4.3
33	39.0	68.2	38.7	56.7	39.0	57.2	34	1.7	54.1	2.0	3.7	2.3	4.3
35	34.1	64.3	33.9	52.7	34.1	53.0	36	1.6	51.1	1.8	3.5	2.1	4.1
37	29.3	60.8	29.1	47.9	29.3	48.2	38	1.4	48.4	1.6	3.3	1.9	3.9
39	25.7	57.7	25.5	44.2	25.7	44.5	40	1.4	46.0	1.6	3.5	1.7	3.7
P	155.3	251.4	154.5	61.5	155.5	61.9					-		-



6. VOLTAGE FLUCTUATIONS & FLICKER TEST

6.1 Block Diagram of Test Setup

Same as Section 6.1.

6.2 Test Standard

EN 61000-3-3:2013/A2:2021

6.3 Operating Condition of EUT

Same as Section 5.3.. The power cord of the EUT is connected to the output of the test system. Turn on the power of the EUT and use the test system to test the harmonic current level.

Flicker Test Limit

Test items	Limits
Pst	1.0
dc	3.3%
Tmax	4.0%
dt	Not exceed 3.3% for 500ms

6.4 Test Procedure

The power cord of the EUT is connected to the output of the test system. Turn on the power of the EUT and use the test system to test the harmonic current level.

6.5 Test Results

PASS

Flicker Test Data			
Temperature:	26℃	Relative Humidity:	60%
Pressure:	1009hPa	Phase :	Vertical
Test Voltage :	AC 230V 50Hz	Test Mode:	Working


Voltage Fluctuation	Limit	Value
Relative Voltage Change Characteristic Tmax (dc>3.3%)	500 ms	0 ms
Maximum Relative Voltage Change dmax	4%	0.00
	6%	/
	7%	/
Relative Steady-state Voltage Change dc	3.3%	0.00

Flicker	Limit	Value
Short-term Flicker Indicator Pst	1.0	0.064
Long-term Flicker Indicator Plt	0.65	/



7. ELECTROSTATIC DISCHARGE IMMUNITY TEST

7.1 Block Diagram of Test Setup



7.2 Test Standard

EN IEC 55014-2:2021, EN 61000-4-2:2009

Severity Level: 3 / Air Discharge: $\pm 8\text{KV}$
Level: 2 / Contact Discharge: $\pm 4\text{KV}$

7.3 Severity Levels and Performance Criterion

7.3.1 Severity level

Level	Test Voltage Contact Discharge (KV)	Test Voltage Air Discharge (KV)
1.	± 2	± 2
2.	± 4	± 4
3.	± 6	± 8
4.	± 8	± 15
X	Special	Special

7.3.2 Performance criterion : B

- A. The apparatus shall continue to operate as intended during the test. No degradation of performance or loss of function is allowed below a performance level (or permissible loss of performance) specified by the manufacturer, when the apparatus is used as i
- B. The apparatus shall continue to operate as intended after the test. No degradation of performance or loss of function is allowed below a performance level (or permissible loss of performance) specified by the manufacturer, when the apparatus is used as intended. During the test, degradation of performance is allowed, however, no change of actual operating state or stored data is allowed. If the minimum performance level or the permissible performance loss is not specified by the manufacturer, then either of these may be derived from the product description and documentation, and from what the user may reasonably expect from the apparatus if used as intended.
- C. Temporary loss of function is allowed, provided the function is self-recoverable or can be restored by the operation of the controls, or by any operation specified in the instructions for use.



7.4 EUT Configuration

The following equipments are installed on Electrostatic Discharge Immunity test to meet EN IEC 55014-2:2021, EN 61000-4-2:2009, requirement and operating in a manner which tends to maximize its emission characteristics in a normal application. The configuration of EUT is the same as used in conducted emission test. Please refer to Section 2.4.

7.5 Operating Condition of EUT

Same as conducted emission measurement, which is listed in Section 3.5 except the test setup replaced by Section 7.1.2.

7.6 Test Procedure

7.6.1 Air Discharge:

This test is done on a non-conductive surface. The round discharge tip of the discharge electrode shall be approached as fast as possible to touch the EUT. After each discharge, the discharge electrode shall be removed from the EUT. The generator is then re-triggered for a new single discharge and repeated 10 times for each pre-selected test point. This procedure shall be repeated until all the air discharge completed.

7.6.2 Contact Discharge:

All the procedure shall be same as Section 7.6.1. Except that the tip of the discharge electrode shall touch the EUT before the discharge switch is operated.

7.6.3 Indirect discharge for horizontal coupling plane

At least 10 single discharges (in the most sensitive polarity) shall be applied at the front edge of each HCP opposite the center point of each unit (if applicable) of the EUT and 0.1m from the front of the EUT. The long axis of the discharge electrode shall be in the plane of the HCP and perpendicular to its front edge during the discharge.

7.6.4 Indirect discharge for vertical coupling plane

At least 10 single discharges (in the most sensitive polarity) shall be applied to the center of one vertical edge of the coupling plane. The coupling plane, of dimensions 0.5m X 0.5m, is placed parallel to, and positioned at a distance of 0.1m from the EUT. Discharges shall be applied to the coupling plane, with this plane in sufficient different positions that the four faces of the EUT are complete illuminated.

7.7 Test Results

PASS

Please refer to the following page.




ESD Test Data				
Temperature:	26℃	Humidity:	60%	
Power Supply :	AC 230V 50Hz	Test Mode:	Working	
Air Discharge: ± 8KV Contact Discharge: ± 4KV				
Test Points	Air Discharge	Contact Discharge	Performance Criterion	Result
Enclosure	±2,4,8KV	N/A	B	PASS
Slit	±2,4,8KV	N/A	B	PASS
Metal Part	N/A	±2,4 KV	B	PASS
VCP	N/A	±2,4 KV	B	PASS
HCP	N/A	±2,4 KV	B	PASS
Note: N/A				



8. RF FIELD STRENGTH SUSCEPTIBILITY TEST

8.1 Block Diagram of Test Setup



8.2 Test Standard

EN IEC 55014-2:2021,
EN IEC 61000-4-3:2020
Severity Level 2, 3V / m

8.3 Severity Levels and Performance Criterion

8.3.1. Severity level

Level	Field Strength V/m
1.	1
2.	3
3.	10
X.	Special



8.3.2. Performance criterion: A

- A、 The apparatus shall continue to operate as intended during the test. No degradation of performance or loss of function is allowed below a performance level (or permissible loss of performance) specified by the manufacturer, when the apparatus is used as i
- B、 The apparatus shall continue to operate as intended after the test. No degradation of performance or loss of function is allowed below a performance level (or permissible loss of performance) specified by the manufacturer, when the apparatus is used as intended. During the test, degradation of performance is allowed, however, no change of actual operating state or stored data is allowed. If the minimum performance level or the permissible performance loss is not specified by the manufacturer, then either of these may be derived from the product description and documentation, and from what the user may reasonably expect from the apparatus if used as intended.
- C、 Temporary loss of function is allowed, provided the function is self- recoverable or can be restored by the operation of the controls, or by any operation specified in the instructions for use.

8.4 EUT Configuration on Test

The following equipments are installed on Electrical Fast Transient/Burst Immunity test to meet EN IEC 55014-2:2021, EN 61000-4-4:2012, requirement and operating in a manner which tends to maximize its emission characteristics in a normal application. The configuration of EUT is the same as used in conducted emission test. Please refer to Section 3.4.

8.5 Operating Condition of EUT

Same as conducted emission measurement, which is listed in Section 2.5 except the test setup replaced by Section 8.1.

8.6 Test Procedure

The EUT and its simulators are placed on a turn table which is 0.8 meter above ground. EUT is set 3 meter away from the transmitting antenna which is mounted on an antenna tower. Both horizontal and vertical polarization of the antenna are set on test. Each of the four sides of EUT must be faced this transmitting antenna and measured individually.

All the scanning conditions are as follows :

Condition of Test	Remarks
1. Fielded Strength	3 V/m (Severity Level 2)
2. Radiated Signal	Modulated
3. Scanning Frequency	80 – 1000 MHz
4. Dwell time of radiated	0.0015 decade/s
5. Waiting Time	1 Sec.

8.7 Test Results

PASS

Please refer to the following page.



R/S Test Data			
Temperature : 26℃		Humidity : 60%	
Field Strength: 3 V/m		Criterion: A	
Power Supply: AC 230V 50Hz		Frequency Range: 80 MHz to 1000 MHz	
Modulation: ☒ AM ☐ Pulse ☐ none 1 KHz 80%			
Test Mode : On			
	Frequency Range : 80-1000MHz		
Steps	1 %		
	Horizontal	Vertical	Result
Front	A	A	Pass
Right	A	A	Pass
Rear	A	A	Pass
Left	A	A	Pass
Note: The EUT is the testing item(s) was (were) fulfilled by subcontracted lab SHENZHEN HAIYUN TESTING CO.,LTD			



9. ELECTRICAL FAST TRANSIENT/BURST IMMUNITY TEST

9.1 Block Diagram of EUT Test Setup



9.2 Test Standard

EN IEC 55014-2:2021, EN 61000-4-4:2012

9.3 Severity Levels and Performance Criterion

Severity Level 2 at 1KV, Pulse Rise time & Duration: 5 nS / 50 nS

Severity Level:

Open Circuit Output Test Voltage $\pm 10\%$		
Level	On power ports	On I/O(Input/Output) Signal data and control ports
1.	0.5KV	0.25KV
2.	1KV	0.5KV
3.	2KV	1KV
4.	4KV	2KV
X.	Special	Special

Performance criterion: B

- A. The apparatus shall continue to operate as intended during the test. No degradation of performance or loss of function is allowed below a performance level (or permissible loss of performance) specified by the manufacturer, when the apparatus is used as i
- B. The apparatus shall continue to operate as intended after the test. No degradation of performance or loss of function is allowed below a performance level (or permissible loss of performance) specified by the manufacturer, when the apparatus is used as intended. During the test, degradation of performance is allowed, however, no change of actual operating state or stored data is allowed. If the minimum performance level or the permissible performance loss is not specified by the manufacturer, then either of these may be derived from the product description and documentation, and from what the user may reasonably expect from the apparatus if used as intended.
- C. Temporary loss of function is allowed, provided the function is self- recoverable or can be restored by the operation of the controls, or by any operation specified in the instructions for use.



9.4 EUT Configuration on Test

The following equipments are installed on Electrical Fast Transient/Burst Immunity test to meet EN IEC 55014-2:2021, EN 61000-4-4:2012, requirement and operating in a manner which tends to maximize its emission characteristics in a normal application. The configuration of EUT is the same as used in conducted emission test. Please refer to Section 3.4.

9.5 Operating Condition of EUT

Same as conducted emission measurement, which is listed in Section 2.6 except the test setup replaced by Section 9.1.

9.6 Test Procedure

EUT shall be placed 0.8m high above the ground reference plane which is a min.1m*1m metallic sheet with 0.65mm minimum thickness. This reference ground plane shall project beyond the EUT by at least 0.1m on all sides and the minimum distance between EUT and all other conductive structure, except the ground plane beneath the EUT, shall be more than 0.5m

9.6.1. For input and output AC power ports:

The EUT is connected to the power mains by using a coupling device which couples the EFT interference signal to AC power lines. Both polarities of the test voltage should be applied during compliance test and the duration of the test is 2 minutes.

9.7 Test Results

PASS

Please refer to the following page

EFT Test Data				
Temperature:	26℃	Humidity:	60%	
Power Supply	: AC 230V 50Hz	Test Mode:	Working	
Coupling Line	Test Voltage		Performance Criterion	Result
	±0.5kV	±1kV		
L	±0.5kV	±1kV	B	PASS
N	±0.5kV	±1kV	B	PASS
L-N	±0.5kV	±1kV	B	PASS
DC Line	/	/		/
Note: N/A				



10. SURGE TEST

10.1 Block Diagram of EUT Test Setup



10.2 Test Standard

EN IEC 55014-2:2021, EN 61000-4-5:2014+A1:2017

10.3 Severity Levels and Performance Criterion

Severity Level: Line to Line, Level 2 at 1KV;

Severity Level: Line to Earth, Level 3 at 2KV.

Severity Level	Open-Circuit Test Voltage (KV)
1.	0.5
2.	1.0
3.	2.0
4.	4.0
X.	Special

Performance criterion: B

- A. The apparatus shall continue to operate as intended during the test. No degradation of performance or loss of function is allowed below a performance level (or permissible loss of performance) specified by the manufacturer, when the apparatus is used as i
- B. The apparatus shall continue to operate as intended after the test. No degradation of performance or loss of function is allowed below a performance level (or permissible loss of performance) specified by the manufacturer, when the apparatus is used as intended. During the test, degradation of performance is allowed, however, no change of actual operating state or stored data is allowed. If the minimum performance level or the permissible performance loss is not specified by the manufacturer, then either of these may be derived from the product description and documentation, and from what the user may reasonably expect from the apparatus if used as intended.
- C. Temporary loss of function is allowed, provided the function is self- recoverable or can be restored by the operation of the controls, or by any operation specified in the instructions for use.



10.4 EUT Configuration on Test

The following equipments are installed on Electrical Fast Transient/Burst Immunity test to meet EN IEC 55014-2:2021, EN61000-4-5:2014+A1:2017, requirement and operating in a manner which tends to maximize its emission characteristics in a normal application

The configuration of EUT is the same as used in conducted emission test.
Please refer to Section 3.4.

10.5 Operating Condition of EUT

Same as conducted emission measurement, which is listed in Section 2.7 except the test setup replaced by Section 10.1.

10.6 Test Procedure

- 1) Set up the EUT and test generator as shown on section 10.1
- 2) For line to line coupling mode, provide a 1KV 1.2/50us voltage surge (at open-circuit condition) and 8/20us current surge to EUT selected points.
- 3) At least 5 positive and 5 negative (polarity) tests with a maximum 1/min repetition rate are conducted during test.
- 4) Different phase angles are done individually.
- 5) Repeat procedure 2) to 4) except the open-circuit test voltage change from 1KV to 2KV for line to earth coupling mode test.
- 6) Record the EUT operating situation during compliance test and decide the EUT immunity criterion for above each test.

10.7 Test Result


PASS

Surge Test Data						
Temperature:		26℃		Humidity:		60%
Power Supply		AC 230V 50Hz		Test Mode:		Working
Location	Polarity	Phase Angle	No of Pulse	Pulse Voltage (KV)	Performance Criterion	Result
L-N	+	90	5	1	B	Pass
	-	90	5	1		Pass
	+	270	5	1		Pass
	-	270	5	1		Pass
Note: N/A						



11. INJECTED CURRENTS SUSCEPTIBILITY TEST

11.1 Block Diagram of EUT Test Setup



11.2 Test Standard

EN IEC 55014-2:2021, EN IEC 61000-4-6:2023

11.3 Severity Levels and Performance Criterion

Severity Level 2: 3V(rms), 150KHz ~ 80MHz

Severity Level:

Level	Field Strength V
1.	1
2.	3
3.	10
X.	Special

Performance criterion: A

- A. The apparatus shall continue to operate as intended during the test. No degradation of performance or loss of function is allowed below a performance level (or permissible loss of performance) specified by the manufacturer, when the apparatus is used as i
- B. The apparatus shall continue to operate as intended after the test. No degradation of performance or loss of function is allowed below a performance level (or permissible loss of performance) specified by the manufacturer, when the apparatus is used as intended. During the test, degradation of performance is allowed, however, no change of actual operating state or stored data is allowed. If the minimum performance level or the permissible performance loss is not specified by the manufacturer, then either of these may be derived from the product description and documentation, and from what the user may reasonably expect from the apparatus if used as intended.
- C. Temporary loss of function is allowed, provided the function is self- recoverable or can be restored by the operation of the controls, or by any operation specified in the instructions for use.

11.4 EUT Configuration on Test

The configuration of EUT is the same as used in conducted emission test.
Please refer to Section 2.8.

11.5 Operating Condition of EUT

Same as conducted emission test, which is listed in Section 2.8 except the test set up replaced as Section 11.1.



11.6 Test Procedure

- 1) Set up the EUT, CDN and test generator as shown in section 11.1
- 2) Let EUT work in test mode and measure.
- 3) The EUT and supporting equipments are placed on an insulating support 0.1m high above a ground reference plane. CDN (coupling and decoupling device) is placed on the ground plane at above 0.1-0.3m from EUT. Cables between CDN and EUT are as short as possible, and their height above the ground reference plane shall be between 30 and 50 mm (where possible).
- 4) The disturbance signal described below is injected to EUT through CDN.
- 5) The EUT operates within its operational mode(s) under intended climatic conditions after power on.
- 6) The frequency range is swept from 150KHz to 80MHz using 3V signal level, and with the disturbance signal 80% amplitude modulated with a 1KHz sine wave
- 7) The rate of sweep shall not exceed 1.5×10^{-3} decades/s. Where the frequency is swept incrementally, the step size shall not exceed 1% of the start and thereafter 1% of the preceding frequency value.
- 8) Recording the EUT operating situation during compliance test and decide the EUT immunity criterion for above each test.

11.7 Test Result

PASS

CS Test Data						
Temperature:		26℃		Humidity:		60%
Power Supply :		AC 230V 50Hz		Test Mode:		Working
Frequency Range(MHz)	Injected Position	Strength	Modulation Signal	Freq. Step	Performance Criterion	Result
150KHz ~ 80MHz	AC Line	3V(rms), Unmodulated	AM 80%, 1kHz sine wave	1%	A	Pass
150KHz ~ 80MHz	DC Line	1V(rms), Unmodulated	AM 80%, 1kHz sine wave	1%	/	/
Note: N/A						



12. VOLTAGE DIPS AND INTERRUPTIONS TEST

12.1 Block Diagram of EUT Test Setup



12.2 Test Standard

EN IEC 55014-2:2021, EN IEC 61000-4-11:2020

12.3 Severity Levels and Performance Criterion

Severity Level:

Input and Output AC Power Ports.

- ☒ Voltage Dips.
- ☒ Voltage Interruptions.

Environmental Phenomena	Test Specification	Units	Performance Criterion
Voltage Dips	70	% Reduction period	C
	25		
	40	% Reduction period	C
	10		
Voltage Interruptions	0	% Reduction period	C
	0.5		

Performance criterion: B, C, C

- A. The apparatus shall continue to operate as intended during the test. No degradation of performance or loss of function is allowed below a performance level (or permissible loss of performance) specified by the manufacturer, when the apparatus is used as i
- B. The apparatus shall continue to operate as intended after the test. No degradation of performance or loss of function is allowed below a performance level (or permissible loss of performance) specified by the manufacturer, when the apparatus is used as intended. During the test, degradation of performance is allowed, however, no change of actual operating state or stored data is allowed. If the minimum performance level or the permissible performance loss is not specified by the manufacturer, then either of these may be derived from the product description and documentation, and from what the user may reasonably expect from the apparatus if used as intended.
- C. Temporary loss of function is allowed, provided the function is self- recoverable or can be restored by the operation of the controls, or by any operation specified in the instructions for use.

12.4 EUT Configuration on Test

The configuration of EUT is the same as used in conducted emission test.
Please refer to Section 2.10.

12.5 Operating Condition of EUT

Same as conducted emission test, which is listed in Section 2.10 except the test set up replaced as Section 13.1.



12.6 Test Procedure

- 1) Set up the EUT and test generator as shown on section 13.1
- 2) The interruption is introduced at selected phase angles with specified duration. There is a 3mins minimum interval between each test event.
- 3) After each test a full functional check is performed before the next test.
- 4) Repeat procedures 2 & 3 for voltage dips, only the level and duration is changed.
- 5) Record any degradation of performance.

12.7 Test Result

PASS

Please refer to the following page.

DIPS Test Data			
Temperature:	26°C	Humidity:	60%
Power Supply :	AC 230V 50Hz	Test Mode:	Working
Environmental Phenomena	Test Specification	Units	Performance Criterion
Voltage Dips	70	% Reduction period	C
	25		
	40	% Reduction period	C
	10		
Voltage Interruptions	0	% Reduction period	C
	0.5		



13. EUT PHOTOGRAPHS

EUT Photo 1



EUT Photo 2





14. EUT TEST PHOTOGRAPHS

RE



CE



***** END OF REPORT *****